

From

The Head
Department of Microbiology
PAU, Ludhiana.

To

Wisdom world school
Road ahmedgarh
Distt-malerkotla

Memo. No.

1844

Dated:

10/4/26

Subject:

Bacteriological quality of drinking water (IS-10500:1991. BIS New Delhi).

Reference is made to your letter No.nil dated 07.04.2026 regarding sample of water for bacteriological analysis.

REPORT

S. No.	Source	Coliform organisms		Faecal Coliform / E. coli Detected / Not detected
		Present/ Absent	Most Probable Number index ($<10/100\text{ml}$)	
12	Water Sample	Absent	-	Not detected

INFERENCE

Bacteriologically safe :- 12

***Bacteriologically not safe :- nil**

Amandeep Singh
Technician

Water Testing Lab
Department of Microbiology
PAU, Ludhiana

Kuldeep
Incharge

Water Testing Lab
Department of Microbiology
PAU, Ludhiana

NOTE: This result relates to the sample provided to us and laboratory is not responsible for drawing/collecting of samples. The contents of this report are meant for your guidance and should not be used for Advertisement, Evidence and Litigation. This test document shall not be reproduced without the permission of the University.

Head
10.4.26

Department of Microbiology

**Treatment for non-potable water as per WHO recommendations: Treat 20L of water with 1mL dose of 10% Sodium hypochlorite or 1.8mL dose of 5% Sodium hypochlorite solutions with retention time of 30 Mins. The water must be used within 24 hours of treatment. The solution is available with all the chemical stores.*

OFFICE OF THE MUNICIPAL COUNCIL AHMEDGARH(MALERKOTLA)

Office Ph.No.01675-240016 mail-id.ddlgp_ahmedgarh@yahoo.com

No. 2256

Date. 15/7/26

TO WHOM IT MAY CONCERN

During the inspection, drinking water, toilets, sewage system, cleaning and sanitation facilities were inspected in the school. Based on the water testing report of the accredited lab submitted, it was found that the drinking water available in the school is safe and potable.


Executive Officer
Ahmedgarh.
Municipal Council Ahmedgarh

Principal,

Wisdom word School,

Dehliz Road, Ahmedgarh channa